



Consumer and  
Corporate Affairs

Consommation et  
corporations

Consumer  
Standards  
Directorate

Direction  
générale  
des normes

SPE-298

Ottawa, Ontario.

Your file    Votre référence

Our file    Notre référence

1145-57/C4-384

March 8, 1976.

SPECIAL APPROVAL

Granted to:    Newfoundland & Labrador Power  
                  P.O. Box 9100  
                  St. John's, Newfoundland

Attention:    Mr. George Sturge  
                  Metering Engineer

Subject:        Three only ASEA Type IMBA72A2, 69Kv, 60 Hz,  
                  200/400/600/800/1000/1200-5-5 Amp. Current  
                  Transformers, Serial No.'s 6298044, 6298045  
                  and 6298046.

Special Approval has been granted by the Standards Directorate, for use in Canada for billing purposes, to the above-named apparatus.

These transformers are used in parallel secondary with three other identical units approved under SPE-156, October 10, 1969.

The nameplate is marked 0.3B1.0 for 200-5 ratio and 0.3B2.0 for all other ratios.

These transformers are for use at Oxen Pond T.S. Trf. No.2 (to Nfld. Light)

D. L. Smith,  
Chief,  
Electricity & Gas Division.

c.c. Mr. J. W. Strachan,  
District Inspector E&G,  
St. John's, Newfoundland