



Consumer and  
Corporate Affairs

Consommation et  
corporations

Consumer  
Standards  
Directorate

Direction  
générale  
des normes

SPE-299

Ottawa, Ontario.

Your file    *Voire référence*

Our file    *Notre référence*

1145-57/C4-384

March 8, 1976.

SPECIAL APPROVAL

Granted to:    Newfoundland & Labrador Power  
                  P.O. Box 9100  
                  St. John's, Newfoundland

Attention:    Mr. George Sturge  
                  Metering Engineer

Subject:        Nineteen only ASEA Type IMBA 72A3, 69 Kv,  
                  60 Hz, 150/200/300/400/600/800-5-5-5 Amp.  
                  Current Transformers, Serial No.'s 5899226,  
                  5899227, 5899228, 5899231, 5899232, 6038230,  
                  6038231, 6038232, 6038233, 6038234, 6038235,  
                  6169738, 6169739, 6169740, 6295795, 6295796,  
                  6474768, 6474769, and 6474770.

Special Approval has been granted by the Standards Directorate,  
for use in Canada for billing purposes, to the above-named  
apparatus.

These transformers, except for the ratings are similar to  
those covered by SPE-116, December 28, 1967.

The secondary windings "X" and "Y" are approved for revenue  
metering and the winding "Z" is intended for relaying service.

The nameplate is marked 0.3 B-1.0 for 150-5 ratio and  
0.3 B-2.0 for all other ratios.

The transformers are for use at the following locations:

Three transformers, Serial No.'s 5899226, 5899231 and  
5899232 at West Avalon Terminal Station, Trf. No.1 (to  
Nfld. Light)

Three transformers, Serial No.'s 6474768, 6474769 and  
6474770 at West Avalon Terminal Station, Trf. No.2 (to  
Nfld. Light)

Three transformers, Serial No.'s 6169738, 6169739 and  
6169740 at Holyrood T.S. (to Nfld. Light)

Three transformers, Serial No.'s 6038230, 6038231 and  
6038232 at Bottom Brook T.S. (to Nfld. Light)

Three transformers, Serial No.'s 6038233, 6038234 and 6038235 at Linton Lake T.S. (to Nfld. Light)

Two transformers, Serial No.'s 5899227 and 5899228 at Massey Drive T.S. (to Bowater Power)

Two transformers, Serial No.'s 6295795 and 6295796 at Massey Drive T.S. Trf. No.2 (to Bowater Power).



D. L. Smith,  
Chief,  
Electricity and Gas Division.

c.c. Mr. J. W. Strachan  
District Inspector E&G  
St. John's, Newfoundland