



Consumer and
Corporate Affairs

Consommation et
corporations

Consumer
Standards
Directorate

Direction
générale
des normes

SPE-300

Ottawa, Ontario.

Your file Votre référence

Our file Notre référence

1145-57/C4-384

March 8, 1976

SPECIAL APPROVAL

Granted to: Newfoundland & Labrador Power
 P.O. Box 9100
 St. John's, Newfoundland

Attention: Mr. George Sturge
 Metering Engineer

Subject: Three only ASEA Type IMBA 120A3, 138 Kv, 60 Hz
 75/100/150/200/300/400-5-5-5 Amp. Current
 Transformers, Serial No.'s 6168102, 6168103
 and 6168104

Special Approval has been granted by the Standards Directorate, for use in Canada for billing purposes, to the above-named apparatus.

These transformers are identical to those previously approved under SPE-116, December 28, 1967.

Accuracy rating of all units, as marked on the nameplate is 0.3 B-1.0, 0.6 B-2.0.

These transformers are for use at Stony Brook T.S. Line 1 (to Nfld. Light)..

D. L. Smith,
Chief,
Electricity and Gas Division.

c.c. Mr. J. W. Strachan
District Inspector E&G
St. John's, Newfoundland