



Consumer and
Corporate Affairs
Standards

Consommation et
corporations
Normes

✓
SPE-303

Ottawa, Ontario.
K1A 0C9

May 6, 1976.

Your file *Voire référence*

Our file *Notre référence*

GL 1145-57/C2-517

6565- C2-35

SPECIAL APPROVAL

Granted to: Canadian General Electric Company Ltd.,
Power Transmission and Distribution Department,
940 Lansdowne Ave.,
Toronto, Ontario.
M6H 3Z4

Attention: Mr. R. D. Maguire,
Manager - Engineering,
Distribution and Specialty Transformer Section.

Subject: Eighteen C.G.E. Type ^{VCM} YCM-230 Voltage Transformers
230000 GrdY/138000-115/69-115/69 volts, 60 Hz.
Serial Nos. 976751 to 976756 inclusive, 977034 to
977039 inclusive, 978859, 978860, 978861, 995248,
995249, and 996220.

Special Approval has been granted by the Standards
Directorate for use of the subject transformers for billing
purposes in Canada.

These transformers are oil filled, cascade type intended
for outdoor use, connected line to ground. They are identical
to those covered by SPE-286 (Apr.7, 1975).

The accuracy rating is 0.3ZZ, 0.3Z-0.3Z. The total
burden connected to the two secondary windings must not
exceed ZZ.

...../2

All twelve transformers are for use by Alberta Power
at the Mildred Lake Sub-Station in Fort McMurray, Alberta.



D. L. Smith, P. Eng.,
Chief,
Electricity & Gas Division.

c.c. Mr. F. Nash, Edmonton
Alberta Power (through Mr. Nash)
Mr. J. Taylor