



Ottawa, Ontario.
K1A 0C9

May 27, 1976.

Your file *Voire référence*

Our file *Notre référence*

G 6565-8

SPECIAL APPROVAL

Granted to: Gloucester Hydro,
 Box 331 - R.R.No.4,
 Ottawa, Ontario.
 K1G 3N2

Attention: Mr. W. R. Thomas,
 Customer Service Superintendent

Subject: Two Supreme Power Supplies Type ONS
 Voltage Transformers 8320 Y/4800-120 volts
 Serial Numbers 66710 and 66006

Special Approval has been granted by the Standards Directorate for use of the subject transformers for billing purposes in Canada.

These are outdoor oil-insulated transformers, designed for distribution service but are to be used temporarily for revenue metering.

The polarity is additive and when viewing the transformers from the secondary terminal side, the marked secondary terminal (X1) is on the right, while the marked primary terminal (H1) is on the left. Only the two secondary terminals marked X1 and X2 are to be used for billing purposes.

The accuracy rating is 0.3ZZ for both transformers.

They are to be installed by Gloucester Hydro at the Rideau Carleton Race Track on Albion Road, Gloucester Township,

They are to be used by Ontario Hydro at Union Carbide Canada Ltd., Sarnia Project, Moore Plant, Sarnia, Ontario.



D.L. Smith,
Chief,
Electricity and Gas Division.

c.c. Mr. J. Fleming, London, Ont.
Ontario Hydro, through Mr. Fleming
Mr. F. W. Mason, Toronto.