Consommation et corporations

Standards

Normes

SPE-308

Ottawa, Ontario. KlA 0C9

July 15, 1976.

Your file Votre référence

Our file Notre rétérance
G 6565-C3-32

SPECIAL APPROVAL

Granted to:

Westinghouse Canada Limited,

Box 5220,

London, Ontario.

N6A 4N6

Attention:

Mr. T. W. Kolator, P.Eng.,

Senior Engineer, Protective Products,

Distribution Apparatus Division.

Subject:

Three only Canadian Westinghouse Type OPC-138 Current Transformers Frequency 60 Hz, Ratio 600-5 amps. Serial Numbers LB60178, LB60179 and

LB60180.

Special Approval has been granted by the Standards Directorate for use of the subject transformers for revenue metering in Canada.

These are post type transformers designed with 1200 ampere-turns and which have an accuracy rating of 0.3 B-2.0.

These transformers are for use at the Memramcook Terminal, Westmoreland Co., of the New Brunswick Electric Power Commission.

D. L. Smith, Chief.

Electricity and Gas Division.

C.C. Mr. Villeneuve, D.I. Fredericton N.B.E.P.C. through Mr. Villeneuve