



September 8, 1976.

Your file    Votre référence

Our file    Notre référence

G-6565-C3-32

SPECIAL APPROVAL

Granted to:        Westinghouse Canada Ltd.,  
                          Box 5220,  
                          London, Ontario.  
                          N6A 4N6

Attention:         Mr. T. W. Kolator,  
                          Senior Engineer,  
                          Protective Products,  
                          Distribution Apparatus Division.

Subject:            Three only Canadian Westinghouse  
                          Type OPC-230 double ratio 300x150-5-5 amp  
                          current transformers with series multiple  
                          primary winding and two secondary windings.  
                          Frequency 60 Hz.

Special Approval has been granted by the Standards Directorate for use of the subject transformers for revenue metering in Canada.

These are post type transformers designed with 1200 ampere-turns and which have an accuracy rating of 0.3 B-2.0.

These transformers are for use at Trail, B.C. by West Kootenay Power & Light.

D. L. Smith,  
Chief,  
Electricity and Gas Division.

c.c. Mr. W. Pura, D.I., (E&G), Vancouver, B.C.  
      West Kootenay Power & Light (through Mr. Pura)