



OTTAWA, Ontario
K1A 0C9

October 28, 1976

Your file *Votre référence*

Our file *Notre référence*

G6565-C3-32

SPECIAL APPROVAL

Granted to: Canadian Westinghouse Company Ltd.,
P.O. Box 5220,
London, Ontario

Attention: Mr. J. E. Highfield, C.E.T.,
Protective Products,
Distribution Apparatus Division.

Subject: Two only Canadian Westinghouse Type RCT-9
Current Transformers, 1000/500/250-5 amperes,
60 Hz. Serial Nos. 769555 and 769556.

Special Approval has been granted by the Standards Directorate for the use of the subject transformers for revenue metering in Canada.

These are ring type transformers of the same description as given for Type RCT-9 in Notice of Approval S-EA-520, except that the subject transformers have tapped secondaries.

The accuracy rating is as follows:

1000-5A	0.3B2.0
500-5A	0.3B0.9
250-5A	0.6B0.5

Ultimate customer Univex Canada Limited,
c/o University of Waterloo,
Waterloo, Ontario.

D.L. Smith,
Chief,
Electricity and Gas Division.

c.c. Mr. N. Beattie, D.I. E&G Hamilton
Mr. G. Timlock P.U.C. Waterloo