



OTTAWA, Ontario

October 29, 1976

Your file Votre référence

Our file Notre référence

6565-S688-43

SPECIAL APPROVAL

Granted to: Ontario Hydro,
 700 University Ave.,
 Toronto, Ontario.

Attention: Mr. R. R. Urquhart,
 Senior Instrumentation Engineer.

Subject: Statrel Type M-32 Interposing Relays

Special Approval has been granted by the Standards Directorate for the use of the subject relay for billing purposes in Canada.

The modification consists of replacing the dry reed relay Type SR-1045 by a SPDT Form "C", Mercury Wetted Contact Relay, C.P. Clare Type HGSM 51111POO.

Output Contact Rating (Resistive Load)
100VA maximum
500V. dc or ac, maximum
2A, maximum

The 150 interposing relays modified under this approval will be identified as Models M32MH and will be used by Ontario Hydro.

Note: The Interposing Relays, Models M32MH must be mounted upright because of the mercury wetted relay used. An arrow and the words "mount upright" indicate the correct mounting configuration.

D.L. Smith,
Chief, Electricity & Gas Division

c.c.All District Inspectors in Ontario Region