



OTTAWA, Ontario.

November 15, 1976.

Your file *Voire référence*

Our file *Notre référence*

G-6565-C377-32

SPECIAL APPROVAL

Granted to: Cegelec Canada Inc.,
 1400 Industrial Boulevard,
 Laprairie, Quebec.
 J5R 2E5

Attention: Mr. Lafrance

Subject: Three only Alsthom-Savoisienne Type IH-145-14
 138 kV, 60 Hz, 600-5-5 ampere Current Trans-
 formers, Ser. Nos. K77451-01-1, -2, -3.

Special Approval has been granted by the Standards Directorate for the use of the subject transformers for metering purposes in Canada.

These are post-type transformers equipped with a single turn hairpin shaped primary winding upon which are threaded two cores, one each for the separate secondary windings. Terminals X1-X2 are assigned to one winding and Y1-Y2 to the other.

The CSA accuracy rating is 0.6 B-0.1, B-0.2, B-0.5, B-0.9; 0.3 B-1.0.

They are for use by N.B. Electric Power Commission at Salisbury, N.B.

D. L. Smith,
Chief,
Electricity and Gas Division.

c.c. Mr. R. Villeneuve,
D.I., E&G, Fredericton.

c.c. N.B.E.P.C. via Mr. Villeneuve.