



Consumer and  
Corporate Affairs  
Standards

Consommation et  
corporations  
Normes

OTTAWA, Ontario.

January 5, 1977.

**SPE-316**

Your file    Votre référence

Our file    Notre référence

G-6565-F2-35

SPECIAL APPROVAL

Granted to:                    Ferranti-Packard Limited,  
                                  Dieppe Road,  
                                  St. Catharines, Ontario.  
                                  L2R 6W9

Attention:                    Mr. B. F. O'Connell,  
                                  Engineering Department.

Subject:                      One only, Ferranti-Packard Type "M69"  
                                  Voltage Transformer 40250-115/67.08 volts,  
                                  60 Hz, Serial No. 2-427610

Special Approval has been granted by the Standards Directorate for use of the subject transformer for billing purposes in Canada.

This is a two bushing transformer, designed for line-to-line primary connection and is the same as the Type "M69" approved under T-13-2, June 4, 1970, except for the voltage ratios and the accuracy rating which is 0.3Z for both ratios of this unit.

Secondary terminals X1-X3 are used for the high ratio and X2-X3 for the low ratio.

It is to be used by Newfoundland and Labrador Hydro at Oxen Pond T.S., St. John's, Newfoundland.

D. L. Smith,  
Chief,  
Electricity and Gas Division.

c.c. Mr. J. Strachan, D.I. of E&G, St. John's, Newfoundland.  
Newfoundland and Labrador Hydro (through Mr. Strachan).