



Consumer and
Corporate Affairs

Standards

Consommation et
corporations

Normes

MR. FOLSON

SPE-319

Ottawa, Ontario.
K1A 0C9

January 31, 1977.

Your file *Votre référence*

Our file *Notre référence*

G-6565-C3-32

SPECIAL APPROVAL

Granted to: Westinghouse Canada Limited,
 London, Ontario.

Attention: Mr. I. Horvat,
 Station Products.

Subject: Three only, Westinghouse Type CCO-150
 Current Transformers, 50/25-5A, 60 Hz,
 Nominal Voltage Class 25 kV. Serial Nos.
 76310008, 76310014 and 76310015.

Special Approval has been granted by Standards Directorate for use of the subject transformers for billing purposes in Canada.

These transformers are similar in construction and appearance to the Type CTOM approved under T-58, October 6, 1970.

They are approved for an accuracy rating of 0.3 B-1.0 on the high ratio, and 0.3 B-0.5 on the low ratio. No accuracy rating is marked on the nameplate.

They are to be used by the Saskatchewan Power Corporation at Northgate Mall, Regina.

D. L. Smith,
Chief,
Electricity and Gas Division.

c.c. Mr. J. Duff,
District Inspector, E&G, Regina.
Saskatchewan Power Corporation (through Mr. Duff)