



Consumer and  
Corporate Affairs  
Standards

Consommation et  
corporations  
Normes

SPE-322

OTTAWA, Ontario  
K1A 0C9

February 7, 1977

Your file    Votre référence

Our file    Notre référence

G-6565-F2-35

SPECIAL APPROVAL

Granted to:    Ferranti-Packard Ltd.,  
Dieppe Road,  
St. Catharines, Ontario  
L2R 6W9

Attention:    Mr. B. F. O'Connell,  
Electrical Engineer

Subject:        One only, Ferranti-Packard Type "RU5"  
Current Transformers, 2000/1000-5A 60 Hz  
Serial No. 2-429702.


Special Approval has been granted by the Standards Directorate for use of the subject transformer for billing purposes in Canada.

The type RU5 in this current rating was approved under T-19 but with a nameplate accuracy rating of 0.3B0.9. This transformer is approved with a nameplate accuracy rating of 0.3B2.0.

Secondary terminals X1-X3 are used for the high ratio and X2-X3 for the low ratio.

This Approval covers the use of this transformer at:

Atelier de Mesurage Special,  
240 Rue St. Maurice,  
Trois Rivieres, Quebec.

  
D.L. Smith,  
Chief,  
Electricity & Gas Division

c.c. Mr. P. A. Lebeau, D.I. E&G Montreal, P Q.  
Hydro Quebec, through Mr. Lebeau.