



February 7, 1977

Your file    Votre référence

Our file    Notre référence

G-6565-F2-35

SPECIAL APPROVAL

Granted to:            Ferranti-Packard Limited  
                          Dieppe Road  
                          St. Catharines, Ontario  
                          L2R 6W9

Attention:            Mr. B. F. O'Connell  
                          Engineering Department

Subject:              Three only, Ferranti-Packard Type MG-35  
                          Voltage Transformers, 14400-120/69.57-208.7/120  
                          Volts, Ratios 120/207:1, 69/120:1, 60 Hz.  
                          Serial Nos. 2-426117, 2-426118 and 2-426119.

Special Approval has been granted by the Standards Directorate for use of the subject transformers for billing purposes in Canada.

These transformers have an insulation class of 35 kV and are the same in appearance as the Type MG-35 approved under T-13, T-13-1 and T-13-2. They have two tapped secondary windings but neither full winding will be used. Therefore this Approval covers the use of the taps only, as follows:

X2-X3 nominal voltage 69.7V  
Y2-Y3 nominal voltage 120V.

The accuracy rating is 0.3ZZ and applies to either tap when there is no burden on the other. The accuracy class is 0.3 for both taps when the total burden divided in any way between them does not exceed ZZ.

These transformers will be used by Gull Island Power Company Limited at the Happy Valley Switchyard, Goose Bay, Labrador.

D. L. Smith  
Chief  
Electricity & Gas Division

pf  
cc J. W. Strachan, D.I., E&G  
St. John's, NFLD.

Gull Island Power Company, through Mr. Strachan.