Consumer and Corporate Affairs

Consommation et corporations

Standards

Normes

SPE-326

Ottawa, Ontario KlA 0C9

February 15, 1977

Your file Votre référence.

Our tile Notre référence

G 6565-F2-32

SPECIAL APPROVAL

Granted to:

Ferranti-Packard Limited

Dieppe Road

St. Catharines, Ontario

L2R 6W9

Attention:

Mr. B. F. O'Connell Engineering Department

Subject:

Three only, Ferranti-Packard Type K138 Current Transformers 300 x 600 - 5 - 5 Amperes, 60 Hz. Serial Nos. 2-429788. 2-429789 and 2-429790.

Special Approval has been granted by the Standards Directorate for use of the subject transformers for billing purposes in Canada.

The Type K 138 was approved under T-76 with a nameplate accuracy rating of 0.3BO.9. These three transformers have a nameplate accuracy rating of 0.3B4.0.

They will be used by the Gull Island Power Company at Churchill Falls, Labrador.

D. L. Smith

Chief

Electricity & Gas Division

cc J. W. Strachan, D.I. of E & G, St. John's, Newfoundland. Gull Island Power Company, through Mr. Strachan.