Consommation et corporations

Standards

Normes

SPE-327

OTTAWA, Ontario KlA OC9

April 15, 1977

Your file Votre référence

Our file Notre référence

6565-C2-32

SPECIAL APPROVAL

Granted to:

Canadian General Electric Co. Ltd.,

201 Woodlawn Road West,

Guelph, Ontario

N1H - 1B8

Attention:

Mr. L. W. Pisters,

Manager - Engineering.

Subject:

Six only, 1000/600-5A bushing ring type current transformers. Serial Nos. 22728, 22729, 22730, 22731,

22732 and 22733.

Special Approval has been granted by the Standards Directorate for use of the subject transformers for revenue metering in Canada.

These transformers will be located in the low voltage bushings of two identical 3-phase power transformers, Serial Nos. 288980 and 288981.

Accuracy rating is 0.6Bl.8 for both ratios. Secondary connections are:

For 1000-5, X1 - X3 For 600-5, X1 - X2

These transformers will be used by Ontario Hydro at the Lively Distribution Station.

D.L. Smith,

Chief,

Electricity & Gas Division.

c.c.Mr. F. W. Mason,

Mr. M. D. Raaflaub

Ontario Hydro through Mr. Raaflaub