



April 18, 1977

Your file *Votre référence*

Our file *Notre référence*

6565-F2-32

SPECIAL APPROVAL

Granted to: Ferranti-Packard Ltd.,
Dieppe Road,
St. Catharines, Ontario
L2R 6W9

Attention: Mr. B. F. O'Connell,
Electrical Engineer

Subject: Four only, Type "RB" 400/200-5A Current
Transformers, Serial Nos. 2-429784, -5,
-6 and -7.

Special Approval has been granted to the Standards Directorate for use of the subject transformers, on the 400-5A rating only, for billing purposes in Canada.

The Type "RB" in standard current ratings of 800 A through 4000 A was approved with an accuracy rating of 0.3B0.9 under Notice of Approval T-12-1. The four subject transformers are specially approved with an accuracy rating of 0.6B0.5 on the 400-5A ratio which is obtained using secondary terminals X1 - X3.

These units are to be used in conjunction with a standby transformer presently located in the Hydro Quebec repair shop in Trois Rivieres.

D.L. Smith
Chief,
Electricity & Gas Division.

c.c. Mr. P. A. Lebeau, Montreal
Hydro Quebec, through Mr. Lebeau