



Consumer and
Corporate Affairs

Standards

Consommation et
corporations

Normes

SPE-329

OTTAWA, Ontario
K1A OC9

April 18, 1977

Your file Votre référence

Our file Notre référence

G 6565-C4-32

SPECIAL APPROVAL

Granted to: Newfoundland and Labrador Hydro,
 P.O. Box 9100,
 St. John's, Newfoundland.

Attention: Mr. Kevin P. Ryan,
 Metering Supervisor.

Subject: Six only, ASEA Type IMBD-145A4, 145kV,
 60 Hz, 800/700/600/500/400/300/200-5-5-5-5 Amp.
 Current transformers, Serial Nos. 6614758,
 6614759, 6614760, 6621533, 6621534 and 6621535.

Special Approval has been granted by the Standards Directorate for use of the subject transformers, on the 400-5 ampere ratio of two secondary windings, for revenue metering in Canada. The approved ratio is obtained from secondary terminals Z3 - Z4 and W3 - W4.

The approved accuracy rating is 0.6B0.1; B0.2, B0.5, B0.9; 0.3B1.0.

These transformers will be used by Newfoundland and Labrador Hydro at Sunnyside Terminal Station, Newfoundland.

D.L. Smith,
Chief,
Electricity & Gas Division.

c.c. Mr. J. Strachan, Newfoundland