



Consumer and  
Corporate Affairs

Consommation et  
corporations

Consumer  
Standards  
Directorate

Direction  
générale  
des normes

KIA OC9

SPE-0331

May 16, 1977

Your file    Votre référence

Our file    Notre référence

G-6565-C3-32

SPE-331

SPECIAL APPROVAL

Granted to:    Westinghouse Canada Limited  
                  London, Ontario

Attention:     Mr. J.E. Highfield  
                  Protective Products  
                  Transformer and Distribution  
                  Apparatus Division

Subject:        Six only, Westinghouse Type RTCT Current  
                  Transformers, 1200-5A, 60 Hz, Serial Nos.  
                  LC88187 to LC 88192 inclusive.

Special Approval has been granted by Standards Directorate for use of the subject transformers for billing purposes in Canada.

These transformers are of a standard toroidal construction similar to the Type "RCT-9" approved under S-EA.520, September 11, 1961 except for larger physical size, leads instead of terminals and no mounting base.

They are approved for an accuracy rating of 0.6 BO.9 as marked on the nameplate.

They are to be used by the Aluminum Company of Canada at Switching Station, Poste Mistassini, Ville Mistassini, P.Q.

D.L. Smith  
Chief  
Electricity and Gas Division

c.c.    Mr. J.O. Bédard  
          District Inspector, E&G, Quebec

Aluminum Company of Canada  
(Through Mr. Bédard)