

SPE-0334

OTTAWA, Ontario

May 30, 1977

Your file Votre référence

Our file Notre référence

G 6565-C4-32

SPECIAL APPROVAL

Granted to: Newfoundland and Labrador Hydro
 P.O. Box 9100
 St. John's, Newfoundland.

Attention: Mr. Kevin P. Ryan,
 Metering Supervisor.

Subject: Three only, ASEA Type IMBD-145-A4
 145 kV, 60 Hz, 800/700/600/500/400/300/200-
 5-5-5-5A Current Transformers. Serial Nos.
 6621533, 6621534 and 6621535.

Special Approval has been granted by the Standards Directorate for use of the subject transformers, on the 400-5A ratio using the "Z" and "W" secondary coils, for revenue metering in Canada. The approved ratio is obtained from secondary terminals Z3-Z4 and W3-W4.

The approved accuracy rating is 0.6 B0.9; 0.3 B1.0.

These transformers will be used by Newfoundland and Labrador Hydro at Sunnyside Terminal Station, Newfoundland.

Special Approval SPE-329, April 18th, 1977 is superseded.



D. L. Smith
Chief,
Electricity and Gas Division.

c.c. Mr. J. Strachan, Newfoundland.