Consumer and Corporate Affairs

Consommation et corporations

SPE-0335 OTTAWA, Ontario

Consumer Standards Directorate Direction générale des normes

Aug. 4, 1977

Votre référence Your file

Out file Notre référence

G 6565-B8-32

SPECIAL APPROVAL

Granted to:

Brown Boveri (Canada) Limited

Systems Division

4000 Trans Canada Highway Pointe Claire, Que. H9R 1B2

Attention:

Mr. A.J. Armstrong

Subject:

Three Brown Boveri Current Transformers

Type AOT 123 FA

Rated Voltage 123 kV

Primary Current 300/600 A (series/parallel)

Secondary Current 5A

Accuracy Rating at 60 Hz 0.3B2.0 Serial Numbers HA 345582, HA 345583,

HA 345584

Special Approval has been granted by the Standards Directorate for use of the subject transformers for revenue metering in Canada.

. These are single phase current transformers, oil immersed, hermetically sealed, equipped with an expansion device allowing the oil to expand without changing the internal pressures, ring-winding type.

These transformers are for use by MacLaren Power Co., and will be installed at the Dufferin Falls Generating Station, Buckingham, Quebec on the DR-1 line to Masson Generating Station.

D.L. Smith

Chief

Electricity and Gas Division

Mr. J. Drolet, D.I. (E&G), Ottawa MacLaren Power Co. (through Mr. Drolet)