



Consumer and  
Corporate Affairs

Consommation et  
corporations

Consumer  
Standards  
Directorate

Direction  
générale  
des normes

OTTAWA, December 7, 1977

SPE-0339

Your file    Votre référence

87-65113

Our file    Notre référence

G-6565-C3-32

SPECIAL APPROVAL

Granted to:    New Brunswick Electric Power Commission  
                  P.O. Box 2000  
                  Fredericton, N.B.

Attention:     Mr. P. Fitzpatrick  
                  Metering Engineer

Subject:        Three only, Westinghouse Canada Ring Type  
                  Current Transformers, 5000 - 5A, 60 Hz,  
                  Serial Nos. LB-74007, LB-74008, and  
                  LB-74009

Special Approval has been granted by the Standards Directorate for the use of the subject transformers for revenue metering in Canada.

These transformers are of toroidal construction and have no tap on the secondary winding.

The RF (rating factor) is 1.0 and the metering accuracy rating is 0.3 B2.0.

They will be used by New Brunswick Electric Power Commission on the station service transformer at Point Lepreau Nuclear Generating Station, Point Lepreau, N.B.

D.L. Smith  
Chief  
Electricity & Gas Division

c.c. Mr. J.R. Villeneuve  
      District Inspector, E&G  
      Fredericton