



Consumer and
Corporate Affairs

Consommation et
corporations

OTTAWA, December 15, 1977

SPF-0341

Consumer
Standards
Directorate

Direction
générale
des normes

Your file Votre référence

Our file Notre référence

G-6565-C4-32

SPECIAL APPROVAL

Granted to: ASEA Limited
10300 Henri-Bourassa Boulevard West
Saint-Laurent, Quebec
Box 700, Postal Station Cartierville
Montreal, Quebec H4K 2J8

Attention: Mr. M. Jemczyk, P.Eng.
Power Department

Subject: Three only, ASEA Type IMBD-145-A3 Current
Transformers with three secondary coils
(X, Y & Z). Nominal secondary current 5-5-5 A.
Serial Nos. 6691469, 6691470 and 6691471.

Three only ASEA Type IMBD-145-A4 Current
Transformers with four secondary coils
(X, Y, Z & W). Nominal secondary current
5-5-5-5 A. Serial Nos. 6691466, 6691467
and 6691468.

All six transformers have the following ratings:
Primary Current 800/700/600/500/400/300/200/
100 A. Nominal Voltage Class 138 kV.
Frequency 60 Hz.


Special Approval has been granted by the Standards
Directorate for use of the subject transformers on the
400 - 5 A ratio of certain secondary coils, in Canada.

The approved ratio is obtained from secondary terminals
X1-X3 on the Type IMBD-145-A3 and secondary terminals
X1-X3 and Y1-Y3 on the Type IMBD-145-A4.

...2

The approved accuracy rating is 0.6 Bl.0.

These transformers will be used by Newfoundland and Labrador Hydro at Sunnyside Terminal Station, Newfoundland.

A handwritten signature in cursive script, appearing to read "D.L. Smith". The signature is written in dark ink and is positioned above the typed name.

D.L. Smith
Chief
Electricity & Gas Division

c.c. Mr. J. Strachan, D.I. (E&G) St. John's
Newfoundland and Labrador Hydro (through Mr. Strachan)