



Consumer and
Corporate Affairs

Consommation et
corporations

Consumer
Standards
Directorate

Direction
générale
des normes

SPE-0342
OTTAWA, December 22, 1977

Your file Votre référence

Our file Notre référence

G-6565-C3-32

SPECIAL APPROVAL

Granted to: Westinghouse Canada Limited
 Box 5220
 London, Ontario
 N6A 4N6

Attention: Mr. T.W. Kolator, P.Eng.
 Senior Engineer
 Protective Products, Transformers and
 Distribution
 Apparatus Division, London

Subject: Three only, Westinghouse Type RCT Current
 Transformers, 3000/1000 - 5 A, 60 Hz, Serial
 Nos. LC-98494, LC-98495 and LC-98496.

Special Approval has been granted by the Standards Directorate for use of the subject transformers for revenue metering in Canada.

These are ring-type transformers similar to the Type RCT approved under T-15, Oct. 4, 1966, which did not include the dual current rating covered by this Notice.

The accuracy rating is 0.3B2.0 for the 3000 - 5 A rating and 0.6 B 0.9 for the 1000 - 5 A rating.

These transformers will be used by Ontario Hydro at Brechin Crushed Stone Limited, Brechin, Hwy. #169, Ontario.

D.L. Smith
Chief
Electricity & Gas Division

c.c. Mr. M. Raaflaub, District Manager, E&G
Toronto

Ontario Hydro (through Mr. M. Raaflaub)