



Consumer and
Corporate Affairs

Consommation et
corporations

Consumer
Standards
Directorate

Direction
générale
des normes

OTTAWA, February 10, 1978

SPE-0345

Your file Votre référence

Our file Notre référence

656-C2-32

SPECIAL APPROVAL

Granted to: Canadian General Electric Company Ltd.,
 940 Lansdowne Ave.,
 Toronto, Ontario.
 M6H 3Z4

Attention: Mr. R. D. Maguire,
 Manager-Engineering,
 Distribution & Specialty Transformer Section

Subject: Ten only CGE Type CTPL-15 Current Transformers,
 1500/750-5A, 60 Hz, Serial Nos. 1073161 to
 1073170 inclusive.

Special Approval has been granted by the Standards Directorate for use of the subject transformers for revenue metering in Canada.

These transformers are identical in construction to those of the same type covered by T-39, but the 750-5A rating is not included in that Notice of Approval.

The accuracy rating marked on the nameplate is 0.3B0.9 for the 1500-5A and 0.6B0.9 for the 750-5A rating.

These transformers are for use by Manitoba Hydro.

D.L. Smith
Chief,
Electricity and Gas Division.

c.c. Mr. J. Bileski, Winnipeg
Manitoba Hydro (Mr. Glover), through Mr. Bileski