



Consumer and
Corporate Affairs Canada

Consommation et
Corporation Canada

SPE-346-1 *SPE-0346 Rev 1*

Consumer Standards
Directorate

Direction générale
des normes

OTTAWA, Ontario,
K1A 0C9

August 2, 1978

Your file *Voire référence*

Our file *Notre référence*

G 6565-C4-32

SPECIAL APPROVAL

Granted to: ASEA Limited
831 Portage Avenue
Suite 100,
Winnipeg, Manitoba
R3G 0N6

Attention: Mr. Brian Burnard, P.Eng.
Power Department - Winnipeg

Subject: Eighteen only, ASEA Type IMBD-245-A4 Current
Transformers with four multi-tapped secondary
coils. Current Ratios 100 x 200/ 300 x 600/
400 x 800/ 500 x 1000/ 600 x 1200 -5-5-5-5A.
Serial Nos. 6598172 to 6598189 inclusive.

This is an amendment to Special Approval No. SPE-346.

By this amendment approval is granted to utilize these
transformers at 800-5A.

<u>Primary Current Rating</u>	<u>Primary Coil Connection</u>	<u>Accuracy Rating</u>
800 - 5	Parallel	0.6 B2.0

D. L. Smith, P.Eng.,
Chief
Electricity and Gas Division