



Consumer and
Corporate Affairs

Consommation et
corporations

Consumer
Standards
Directorate

Direction
générale
des normes

SPE-347

Ottawa, Ontario
K1A 0C9

May 9, 1978
You like. Value reference.

Our file. Notre référence.

G-6565-C3-32

SPECIAL APPROVAL

Granted to: Westinghouse Canada Limited
Box 5220
London, Ontario
N6A 4N6

Attention: Mr. R. L. Wood, P.Eng.,
Production Engineering Supervisor,
Transformer and Distribution Apparatus
Division - London

Subject: Eight only, Westinghouse Canada Ring
Type Current Transformers, 8500-2.5A
60 Hz, Serial Nos. LC 93158, LC 93159,
LC 96957, LC 96958, LC 61939, LC 61940,
LD 62168 and LD 62169.

Special Approval has been granted by the Standards Directorate for use of the subject transformers for revenue metering in Canada.

These transformers are of toroidal construction having an inside diameter of 16 inches and an outside diameter of 20 inches. The RF (rating factor) is 1.0 and the accuracy rating is 0.3 B2.0. There is no tap on the secondary winding of which the terminal leads are marked X1 & X2.

They will be used by New Brunswick Electric Power Commission, at their Lepreau Nuclear Generating Station, Point Lepreau, N.B.

D. L. Smith
Chief,
Electricity and Gas Division

c.c. Mr. J. R. Villeneuve, D.I. (E & G) Fredericton
N.B.E.P.C. (through Mr. Villeneuve)