



Consumer and
Corporate Affairs Canada

Consommation et
Corporation Canada

SPE-0348

Consumer Standards
Directorate

Direction générale
des normes

OTTAWA, July 12, 1978

Your file / Votre référence

Our file / Notre référence

G 6565-F2-33

SPECIAL APPROVAL

Granted to: Ferranti-Packard Limited
 Dieppe Road
 St. Catharines, Ontario
 L2R 6W9

Attention: Mr. B. F. O'Connell, P.Eng.
 Instrument Transformer Engineering

Subject: Three only, Type CSS-15 Single Phase Metering
 Outfits, 500/ 250-5A; 12470 Grd Y/7200-120 V
 Serial Nos. 2-440366, 2-440367 and 2-440368

Special Approval has been granted by the Consumer Standards Directorate for use of the subject transformers for revenue metering in Canada.

These metering outfits contain one Type MC-15 Voltage Transformer approved under SD:EA-358, May 30, 1958, and one Type E8.7 Current Transformer for which previous Notices of Approval do not include the 500/250-5A ratio.

The voltage transformer has an accuracy rating of 0.3ZZ. That of the current transformer is 0.3B0.9 with a RF 1.5.

These units will be used by Manitoba Hydro at Waverly Service Center, Winnipeg, Manitoba.

D. L. Smith
 Chief
 Electricity and Gas Division
 Metrology Branch

c.c. Mr. J. Bileski, D.M. (E&G) Winnipeg
 Manitoba Hydro (Mr. Glover) through Mr. Bileski