



Consumer and
Corporate Affairs Canada

Consommation et
Corporation Canada

SPE-353

OTTAWA, November 14, 1978

Consumer Standards
Directorate

Direction générale
des normes

Your file Votre référence

Our file Notre référence

6565-087-32

SPECIAL APPROVAL

Granted to: Ontario Hydro,
 700 University Ave.,
 Toronto, Ontario
 M5G 1X6

Attention: Mr. R. R. Urquhart,
 Senior Control & Metering Engineer.

Subject: Six only, Eastern Power Devices Bushing
 Type 3000-5A Current Transformers Frequency
 60 HZ, Serial Nos. 72729, 72730, 72731, 72732,
 72733 and 72734.

Special Approval has been granted by the Legal Metrology Branch for use of the subject transformers for revenue metering in Canada.

These are single secondary, ring-type transformers which have an accuracy rating of 0.3B0.9; 0.6B1.8.

They will be used by Ontario Hydro at the Chats Falls generating station.

D.L. Smith,
Chief,
Electricity and Gas Division.

c.c. J. Drolet, D.M. E&G, Ottawa