Consumer and Corporate Affairs Canada

Consommation et Corporation Canada SPE-0354 OTTAWA, Ontario

KIA OC9

Consumer Standards Directorate

Direction générale des normes

November 3, 1978

. G 6565-S2-35

SPECIAL APPROVAL

Granted to:

Societe d'electrolyse et de chimie Alcan Ltee.

Arvida, Quebec, Canada

Attention:

Pierre Bouchard Alcan Consultant

Subject:

Six only, Sangamo Type ME-FORM-6 60Hz Voltage Transformers. Voltage rating 66.4 - 115 volts. Serial Nos. 467607, -08, -09, -10, -11, and -12.

Special Approval has been granted by the Legal Metrology Branch for use of the subject transformers for billing purposes in Canada.

These transformers are identical in design to those approved under T-67-1, except for the non-standard voltage rating.

The accuracy rating is 0.3W, 0.6x as marked on the nameplate.

They will be used by Alcan for their project on Line No. 2326.

D. L. Smith Chief, Electricity and Gas Division

Mr. P. Lebeau, D.I., E & G, Montreal M. Mike Girwood, Aluminium du Canada Ltee C.P. 10, Arvida Quebec