



Consumer and  
Corporate Affairs Canada

Consommation et  
Corporation Canada

OTTAWA, Ontario  
K1A 0C9

Consumer Standards  
Directorate

Direction générale  
des normes

November 9, 1978

Your file    votre référence

Our file    Notre référence  
G 6565-U78-35

SPECIAL APPROVAL

Granted to:            Montel Inc.,  
                              515 Boul. Lebeau  
                              St. Laurent, Québec  
                              H4N 1S2

Attention:             Mr. Georges Simard  
                              Junior Engineer  
                              Electrical Division

Subject:                Three only, Balteau Type "UEX-220" 60Hz Voltage  
                              Transformers, Voltage rating 230,000 GrdY/138000  
                              -69-69 V Ratio 2000:1 :1. Serial Nos 77/51.014/01,  
                              77/51.014/02 and 77/51.014/03.

Special Approval has been granted by the Legal Metrology Branch for use of the subject transformers for billing purposes in Canada.

These oil immersed transformers employ an epoxy resin tank at the base, upon which the porcelain insulation is mounted vertically and supports the expansion head which contains the high voltage terminal.

The accuracy rating marked on the nameplate is 0.6Z for each of the two secondary coils. The 0.6 class applies to both coils for a total burden of "ZZ" provided the burden on either does not exceed "Z".

The transformers will be used by Ontario Hydro at St. Lawrence T.S., Cornwall, Ontario

D. L. Smith  
Chief, Electricity and Gas Division

c.c. Mr. J. Drolet, D.M. E & G, Ottawa, Ontario  
Ontario Hydro (through Mr. Drolet)