



Consumer and  
Corporate Affairs Canada

Consommation et  
Corporation Canada

SPE-357

OTTAWA, Ontario  
K1A 0C9

Consumer Standards  
Directorate

Direction générale  
des normes

November 23, 1978

Your file    Votre référence

Our file    Notre référence

6565-C377-35  
JO #A-1186

SPECIAL APPROVAL

Granted to:    Cegelec Canada Inc.,  
                  1400 Industrial Blvd.,  
                  Laprairie, Quebec,  
                  J5R 2E5

Attention:     Mr. F. Lafrance

Subject:        Three only Alsthom-Savoisienne Type  
                  UH765-16 Voltage Transformers, Voltage  
                  Rating 720,000 GrdY/414,000-110.4-69V  
                  Ratios 3750:1, 6000:1, Serial Nos. K78612-01-1,  
                  K78612-01-2 and K78612-01-3.

Special Approval has been granted by the Legal Metrology Branch for use of the subject transformers for billing purposes in Canada.

These transformers have an insulation class of 765 kV and are equipped with two secondary coils.

The nominal secondary voltages are:

110.4 volts from X1-X2  
69 volts from Y1-Y2.

The accuracy rating for the "X" coil is 0.3ZZ. The 0.3 class applies for a total burden of ZZ.

The accuracy rating of the "Y" coil is 0.6Z. The 0.6 accuracy class applies for a total burden of ZZ, provided the burden on the "Y" coil does not exceed Z.

These transformers will be used by Hydro Quebec at the Abitibi Sub-Station.

D.L. Smith,  
Chief, Electricity & Gas Division.

c.c. Mr. P. Lebeau, D.M. E&G, Montreal  
Hydro Quebec (through Mr. Lebeau)