



Consumer and  
Corporate Affairs Canada

Consommation et  
Corporation Canada

SPE-358

Consumer Standards  
Directorate

Direction générale  
des normes

OTTAWA, Ontario  
K1A 0C9

November 28, 1978

Votre No. Votre référence

Our No. Notre référence

G 6565-F2-35  
JO #A-1188

SPECIAL APPROVAL

Granted to: Ferranti-Packard Limited,  
Dieppe Road,  
St. Catherines, Ontario.  
L2R 6W9

Attention: Mr. B. O'Connell,  
Supervisor,  
Metering & Instrument Department.

Subject: Six only, Ferranti-Packard Type MG-138  
Voltage Transformers, 138000 Grd. Y/78000-  
120-120 V, 60 Hz, Serial Nos. 2-434744,  
-5, -6, -7, -8 and -9.

Special Approval has been granted for use of the subject transformers for revenue metering in Canada.

These transformers are identical to the Type "MG 138" approved under Notice of Approval T-78, March 28, 1972 except for their non-standard voltage rating 138000 Grd Y/78000-120-120V.

Their accuracy rating is 0.3ZZ for either secondary coil when there is no burden on the other. The accuracy class is 0.3 for both coils when the total burden divided in any way does not exceed "ZZ".

These transformers will be used by B.C. Hydro & Power Authority but have not yet been installed.

D.L. Smith,  
Chief,  
Electricity & Gas Division.

c.c. Mr. W. Pura, D.M. (E&G), Vancouver  
B.C. Hydro Power & Authority (through Mr. Pura)