



Consumer and
Corporate Affairs Canada

Consommation et
Corporation Canada

Urbain, CHARRON
K1A 0C9

Consumer Standards
Directorate

Direction générale
des normes

November 30, 1978

Your file Votre référence

Our file Notre référence

6565-C2-32
JO #A-1169

SPECIAL APPROVAL

Granted to: Société d'électrolyse et de chimie Alcan Ltée
Exploitation Energie électrique, Quebec
case postale 800
Arvida, Quebec
G7S 4R5

Attention: M. Pierre Ferland ing
Group: Protection of Communication

Subject: Item 1
Six only, C.G.E. Type BR 60Hz
1200-5A Current Transformers Serial Nos.
284465, 284466, 284468, 284470, 284472
and 284473. Accuracy rating 0.3B2.0

Item 2
Nine only C.G.E. ring type 1200-5A
Current Transformers. Identification Nos.
D-10937-1B-6B-A D-10937-6B-6C-C
D-10937-3B-6B-B D-10937-1B-5B-A
D-10937-5B-6B-C D-10937-3B-5B-B
D-10937-2B-6C-A D-10937-5B-5B-C
D-10937-4B-6C-B
Accuracy rating 0.6B0.5

Special Approval has been granted by the Legal Metrology Branch for the use of the subject transformer for billing purposes in Canada.

These transformers will be used by Alcan at the Mistassini station. Those of "Item 1" will be used on Lines #31 and #55, while those of "Item 2" will be used on lines #1630 and #1939.

D.L. Smith,
Chief,
Electricity and Gas Division.

c.c. Mr. P.A. Lebeau, D.M. E&G, Montreal ✓
Hydro Quebec (through Mr. Lebeau)