



Consumer and
Corporate Affairs Canada

Consommation et
Corporation Canada

SPE-360

Consumer Standards
Directorate

Direction générale
des normes

OTTAWA, Ontario
K1A 0C9

January 2, 1979

Quête *Norme* *reference*

Quête *Norme* *reference*

G-6565-Q31

SPECIAL APPROVAL

Granted to: Hydro-Québec
1405 boul. Henri Bourassa
Québec 3
G1K 3B5

Attention: M. Jos Grenier,
Chef de section mesurage

Subject: Four only, Haliburton and White 4000-5A
Ring-Bushing Type Current Transformers.
Frequency 60 Hz Serial Nos. C-512, C-513,
C-518 and C-519

Special Approval has been granted by the Legal Metrology Branch for use of the subject transformers for billing purposes in Canada.

The accuracy rating is 0.6B0.9 and the R.F. (rating factor) is 1.0.

They will be used by Hydro-Québec at Reed Paper Co.,
boul., Capucins Quebec P.Q.

D. L. Smith
Chief,
Electricity and Gas Division

c.c. M. J.O. Bédard, D.M., E&G (Québec)
Hydro-Québec (through Mr. Bédard)