



Consumer and
Corporate Affairs Canada

Consommation et
Corporation Canada

Consumer Standards
Directorate

Direction générale
des normes

SPB ⁰³⁶²

OTTAWA, Ontario
K1A 0C9

April 9, 1979

Your file Votre référence

Our file Notre référence

G 6565-C4-32

SPECIAL APPROVAL

Granted to: ASEA Limited
 The Bentall Centre
 P.O. Box 49038
 Vancouver, B.C.
 V7X 1C4

Attention: Mr. F. A. da Costa
 Power Department, Vancouver

Subject: Nine only, ASEA IMBE-245-A4 Current Transformers
 with Four Multi-Tapped Secondary Coils. Current
 Ratios 400-600-800-1200-2000/5/5/5/5A. Serial
 Nos. 7137659 to 7137667 inclusive.

Special Approval has been granted by the Standards Directorate for the subject transformers to be used for revenue metering in Canada.

Accuracy ratings for the approved ratios are:

0.6B1.0 at 400/5
0.3B1.0 at 600/5 and 800/5
0.3B2.0 at 1200/5 and 2000/5

The 9 transformers will be used by Calgary Power Ltd. at the Sundance Steam Plant, Sundance, Alberta, 240 KV substation.

D. L. Smith, P.Eng.,
Chief,
Electricity and Gas Division

c.c. Mr. L. Hewitt, D.M., E & G, Calgary
Calgary Power Ltd. (through Mr. Hewitt)