



Consumer and  
Corporate Affairs Canada

Consommation et  
Corporation Canada

SPE-364-Rev. 1

Consumer Standards  
Directorate

Direction générale  
des normes

OTTAWA, September 25, 1979

Your file    Votre référence

Our file    Notre référence

6565-U78-32

SPECIAL APPROVAL

Granted to:    Montel Inc.,  
                  515, boul. Lebeau,  
                  St. Laurent, Quebec  
                  H4N 1S2

Attention:     Mr. J. J. Humbert-Droz,  
                  Electrical Division

Subject:        Three only, Balteau Type QDR-245 Current  
                  transformers, Insul. E1 245kV 60 Hz  
                  Current ratios 150x300, 200x400, 250x500,  
                  400x800, 550x1100, 600x1200, 750x1500,  
                  800x1600, 1000x2000-5/5/5/5A.  
                  Serial Nos. 77/53389-12, -13 and -14.

This is an addition to Special Approval SPE-364, April 24, 1979 which remains in effect. By this addition, the use of terminals Z2-Z3 to give a ratio of 800-5A is approved.

Accuracy rating with this connection is 0.6B1.0.

D.L. Smith,  
Chief,  
Electricity and Gas Division

c.c. Mr. W. Pura, D.M. E&G, Vancouver  
Alcan Smelters & Chemicals (via Mr. Pura)  
B.C. Hydro Power Authority (via Mr. Pura)