



Consumer and
Corporate Affairs Canada

Consommation et
Corporation Canada

SPE-365

Consumer Standards
Directorate

Direction générale
des normes

Ottawa, Ontario
May 1, 1979

Your file Votre référence

Our file Notre référence

6565-C3-32

SPECIAL APPROVAL

Granted to: Westinghouse Canada Limited,
 Box 5220,
 London, Ontario
 N6A 4N6

Attention: Mr. T. W. Kolator, P. Eng.,
 Senior Engineer,
 Protective Products, Transformers and Distribution,
 Apparatus Division, London.


Subject: Three only, Westinghouse Type RCT-15
 Current Transformers, 1500/750-5A, 60 Hz,
 Serial Nos. LE-64763, LE-64764 and LE-64765

Special Approval has been granted by the Legal Metrology Branch for use of the subject transformers for billing purposes in Canada.

These are ring type transformers similar to the type RCT approved under T-15, Oct. 4, 1966, which did not include the dual current rating covered by this Notice.

The accuracy rating is 0.3B2.0 for the 1500-5A rating and 0.3B0.9 for the 750-5A.

These transformers will be installed by Lenrose Electric for United Feed Mills at Lethbridge, Alberta.


D.L. Smith,
Chief,
Electricity and Gas Division.

c.c. Mr. L. Hewitt, D.M. E&G, Calgary
Lenrose Electric (via Mr. Hewitt).