



Consumer and  
Corporate Affairs Canada

Consommation et  
Corporation Canada

SPE-366

OTTAWA, Ontario  
July 6, 1979

Consumer Standards  
Directorate

Direction générale  
des normes

Your No.    Votre référence

Our No.    Notre référence

G6565-C4-32

SPECIAL APPROVAL

Requested by:    ASEA Limited,  
The Bentall Centre, Box 49038  
Vancouver, B.C. V7X 1C4

Attention:        Mr. F.A. da Costa,  
Power Department.

Subject:           Three only, ASEA Type IMBD-145-A1  
400 x 800-5A, 60 Hz Current Transformers  
Serial Nos. 7150144, 7150145 and 7150146

Special Approval has been granted by the Legal Metrology Branch for use of the subject transformers for billing purposes in Canada.

They are similar in design to those approved under T-64, May 27, 1971.

The accuracy rating is 0.3B2.0 and rating factor is 1.2.

These transformers will be used by Calgary Power Ltd. at the Janet substation.

D.L. Smith,  
Chief,  
Electricity and Gas Division.

c.c. Mr. L. Hewitt,  
District Manager E&G  
Calgary Power through Mr. L. Hewitt