



Consumer and
Corporate Affairs Canada

Consommation et
Corporation Canada

OTTAWA, Ontario
K1A 0C9
SPE-0367

Consumer Standards
Directorate

Direction générale
des normes

July 17, 1979

Your file Votre référence

Our file Notre référence

6565-C2-35

SPECIAL APPROVAL

Granted to: Canadian General Electric Co. Ltd.,
201 Woodlawn Road West,
Guelph, Ontario
N1H 1B8

Attention: Mr. W.C. Sandrock, P. Eng.,
H.V. Instrument Transformers

Subject: Four Only Canadian General Electric
Type CVIA Capacitor Voltage Transformers
550000 Grd Y/310500-115/69-115/69 volts
Ratios 2700-4500:1

Special Approval has been granted by the Legal Metrology Branch for use of the subject transformers for billing purposes in Canada.

These transformers are similar in design to those for which Special Approval was granted under SPE-301, March 17, 1976 for use by Manitoba Hydro.

Assembly must be such that the capacitor units bear the same serial number as the corresponding base.

The accuracy rating is 0.3Y; 0.6Z for both coils and taps. The 0.3 class applies when the total secondary burden on the transformer does not exceed "Y". The 0.6 class applies for higher burdens of which the total does not exceed "Z".

This approval is valid only for the following assembly and connections:

CVT Ser. No.	Inst. Transf. Ser. No.	Tap Bushing	H3				Gnd
10357	1064326	H2	1	2-7	6-B	E-A	A
10358	1064042	H2	1	2-5	7-E	G-B	A
10359	1064043	H2	1	2-7	6-G	B-F	A
10360	1064040	H2	1	2-4	8-E	A-G	C

These transformers will be used by Manitoba Hydro
at Dorsey Station.



D.L. Smith,
Chief,
Electricity and Gas Division

c.c. Mr. Sayers, A/D.M., Winnipeg
Manitoba Hydro (via Mr. Sayers)