Consumer and Corporate Affairs Canada

Consumer Standards Directorate Consommation et Corporation Canada

Direction générale des normes

SPE-371

OTTAWA, Ontario Kla OC9

August 20, 1979

Your Ne Voire rélérence

Our Me Notre rélavence G6565-U78-32

## SPECIAL APPROVAL

Granted to:

Montel, Inc.,

Groupe Sprecher & Schuh,

515 boul. Lebeau, St. Laurent, Quebec,

H4N 1S2

Attention:

Georges Simard, Jr. Eng.,

Electrical Division.

Subject:

Three only, Balteau Type QDR-245 60Hz, 245 kV Current Transformers. Current

Ratios 100x200, 300x600, 400x800, 500x1000 and 600x1200-5A Serial Nos. 78/51.086/01,

02 and 03.

Special Approval has been granted by the Legal Metrology Branch for use of the subject transformers for billing purposes in Canada on the above listed ratios except the 100x200-5A one which does not meet the accuracy requirements for approval.

The cores and coils of these transformers are accommodated in the transformer head, above the porcelain insulator.

There are four secondary coils, designated w, x, y and z, each with four terminals.

The terminals used for the approved ratios and the accuracy ratings are as follows:

Terminals for all four coils	Current Ratio	Accuracy Rating
2-3	300x600-5A	0.3B0.5
1-3	400x800-5A	0.3B0.5
2-4	500x1000-5A	0.3Bl.0
1-4	600x1200-5A	0.3B2.0

These transformers are to be used by Manitoba Hydro at Minitonas sub-station.

D.L. Smith,

Chief,

Electricity and Gas Division.

c.c. Mr. W. Sayers
A/District Manager E&G, Winnipeg
(Manitoba Hydro, via Mr. W. Sayers