



Consumer and
Corporate Affairs Canada

13. *Adelcom*
SPE-373
Consommation et
Corporation Canada

OTTAWA, September 25, 1979

Consumer Standards
Directorate

Direction générale
des normes

Your file Votre référence

Our file Notre référence

6565-1

SPECIAL APPROVAL

Granted to: New Brunswick Electric Power Commission,
527 King Street,
Fredericton, N.B.
E3B 4X1

Attention: Mr. W. A. Patterson,
Manager of Systems Operations.

Subject: Three only, Trafo Union Type ART 0/4
Multi-ratio, Bushing Type Current Transformers
Serial Nos. 516990, 516991 and 516992.

Special Approval is hereby granted by the Legal Metrology Branch for use of the subject transformers, on the 1000-5A ratio only, for billing purposes in Canada.

The accuracy rating is 0.6B0.2

Rating factor (RF) is 1.2.

These transformers are for use by the N.B. Electric Power Commission in the Beechwood, N.B./Flo's Inn, Maine interconnection.

D.L. Smith,
Chief,
Electricity and Gas Division.

c.c. Mr. R. C. Bruce, D.M. E&G, Halifax
Mr. H. L. Fraser, N.E.B.