



Consumer and
Corporate Affairs Canada

D. L. Smith
Consommation et
Corporation Canada

SPE-374

OTTAWA, October 19, 1979

Consumer Standards
Directorate

Direction générale
des normes

Your file Votre référence

Our file Notre référence

G-6565-C4-32

SPECIAL APPROVAL

Requested by: ASEA Limited,
 The Bentall Centre, Box 49038
 Vancouver, B.C.
 V7X 1C4

Attention: Mr. F. A. da Costa,
 Power Department.

Subject: Six only, ASEA Type IMBD-145-A3
 1200/1000/800/600/400/200-5-5-5A, 60 Hz,
 Current Transformers. Serial Nos.
 7146574 to 7146579 inclusive.

Special Approval has been granted by the Legal Metrology Branch for use of the subject transformers, on certain ratios, for billing purposes in Canada.

The secondary terminals to be used for obtaining the approved ratios are Z1-Z4 for 1200-5A and Z2-Z3 for 600-5A.

The accuracy rating is 0.3B2.0 for both these ratios.

These transformers will be used by the City of Lethbridge.

D.L. Smith,
Chief, Electricity & Gas Division.

c.c. Mr. L. Hewitt, DM E&G, Calgary
City of Lethbridge via Mr. Hewitt.