



Consumer and
Corporate Affairs Canada

Consommation et
Corporation Canada

Consumer Standards
Directorate

Direction générale
des normes

SPE-315

OTTAWA, Ontario
K1A 0C9

November 15, 1979

Your file Votre référence

Our file Notre référence

G 6565-C377-32

SPECIAL APPROVAL

Granted to: Cegelec Canada Inc.
1400 Boulevard Industrial
Laprairie, Québec
J5R 2E5

Attention: Mr. Francois Lafrance

Subject: Four only Alsthom-Savoisienne type IH 245-24,
600 x 1200-5, 60Hz Current Transformers
Serial Numbers K83-241-01 - 1, 2, 3 & 4.

Special approval has been granted by the Legal Metrology Branch for use of the subject transformers for billing purposes in Canada.

The two ratios of 600 x 1200-5 are obtained by connecting the primary windings in parallel or in series. The accuracy rating is 0.3B2.0.

The transformers will be used by B.C. Hydro and Power Authority at their Vernon Terminal Station, Vernon, B.C.

D. L. Smith,
Chief,
Electricity and Gas Division
Legal Metrology Branch

c.c. Mr. W. Pura, D.M., E & G Vancouver
B.C. Hydro (through Mr. W. Pura)