



Consumer and
Corporate Affairs Canada

Consommation et
Corporation Canada

SPE-376

Consumer Standards
Directorate

Direction générale
des normes

OTTAWA, Ontario
K1A 0C9

January 18, 1980

Your file Votre référence

Our file Notre référence

G 6565-L1-5

SPECIAL APPROVAL

Granted to: Hydro Quebec
 201 Jarry Street West
 Montreal, Quebec
 H2P 1S7

Attention: Mr. Robert Foisy
 Head, Electrical Metering

Subject: Nine (9) Landis & Gyr, Type FFP7hr6f1
 Watt-hour Meters converted to "Q Hour"
 Meters bearing serial numbers 35903631,
 39371076, 39371077, 39371078, 39371079,
 36864055, 35903632, 35903633, 35903634
 and bearing type designation FFP7hr6f1Q.

Special approval is hereby granted by the Legal Metrology Branch for use of the subject meters for billing purposes in Canada.

Modification consists of the following

1. Changing the internal wiring connections so that the voltage associated with each current coil is effectively shifted backwards in time by 60 degrees.
2. Adding the letter "Q" to the end of the type designation number
3. Changing the units designation to Qh on the nameplate and kQh on the register
4. Changing the wiring diagram inside the meter to correspond with the actual internal meter connections.

The subject meters will be used in conjunction with type FFP7hr6f1 watt-hour meters in a summation installation including a Landis & Gyr GAB2.8 summator and a magnetic tape recorder at the firm of "Fer et Titane" of Tracy, Quebec.

J. Armstrong
Acting Chief,
Electricity and Gas Division

c.c. Mr. P. Lebeau E&G Montreal