



Consumer and
Corporate Affairs

Consommation et
corporations

Consumer
Standards
Directorate

Direction
générale
des normes

SPE-378

OTTAWA, Ontario
K1A 0C9

February 22, 1980

Your file Votre référence

Our file Notre référence

G 6565-F2-32

SPECIAL APPROVAL

Granted to: Alcan Smelters and Chemicals Limited
 Power Operations, Quebec
 P.O. Box 800
 Arvida, Quebec
 G7S 4R5

Attention: Mr. E.W. Taylor, Eng.

Subject: Six only Ferranti-Packard Type RB
 60Hz Current Transformers. Current
 rating 6000-5A. Serial Nos.: 2-472507
 to 2-472512 inclusive

Special approval has been granted by the Legal Metrology Branch for use of the subject transformers for revenue metering in Canada for a temporary period of one (1) year. Accuracy rating 0.3B1.8.

The type RB was approved under T-12-1, June 12, 1972 in other current ratings, including 1200-5A.

Three (3) of these transformers will be used by Alcan Smelters and Chemicals Limited at their Beauharnois transformer site T2.

J. Armstrong
Acting Chief
Electricity and Gas Division

cc: Mr. P. Lebeau
 District Manager (E & G)
 Montreal, P.Q.