日本

Consumer and Corporate Affairs

Consommation et corporations

Consumer Standards Directorate Direction générale des normes SPE-379

- 1-11.30m

OTTAWA, Ontario KlA 0C9

Your file - Votre reférence

G 6565-C2-35

SPECIAL APPROVAL

MAR 3 1 1980

Granted to:

Ontario Hydro

700 University Avenue

Toronto, Ontario M5G 1X6.

Attention:

Mr. R.R. Urguhart

Sr. Control and Metering Engineer

Location H5-C17

Subject:

Two only, CGE Type E-116L Voltage

Transformers, 46000-115V 60Hz Serial Nos. 273248 and 273249

Special approval has been granted by the Legal Metrology Branch for the use of the subject transformers for revenue metering in Canada.

The Type E-116L was approved under Notice of Approval SD-EA.91, January 13, 1953. This approval covers the use of the subject transformers over a voltage range from 32% of nominal to 110% of nominal.

They are equipped with two secondary coils, each with an accuracy rating of 0.6Z. The 0.6 accuracy class applies for a total burden on both coils of "zz" provided the burden on either one does not exceed Z.

These transformers will be used at Lake Ontario Steel Co., Whitby, Ontario.

J. Armstrong Acting Chief

Electricity and Gas Division Legal Metrology Branch

cc: M.D. Raaflaub
District Manager
Electricity and Gas
Toronto, Ontario