



Consumer and
Corporate Affairs

Consommation et
corporations

Consumer
Standards
Directorate

Direction
générale
des normes

SPE-380

OTTAWA, Ontario
K1A 0C9

Your file / Votre référence

Our file / Notre référence

G 6565-C4-32

MAR 31 1980

SPECIAL APPROVAL

Granted to: ASEA Limited
The Bentall Centre
P.O. Box 49038,
Vancouver, B.C.
V7X 1C4

Attention: Mr. F.A. da Costa
Power Department

Subject: Six only, ASEA type IMBD-245-A2 Current
Transformers, 200/400/600/800/1200 - 5A
60Hz -- Serial Nos. 6479-704, -705, -706
and 6512-349, -350, -351

special approval has been granted by the Legal Metrology Branch for use of the subject transformers on the 1200-5A current rating only, for revenue metering in Canada.

The approved ratio is obtained from secondary terminals X1-X4 and Y1-Y4, and the accuracy rating is 0.3B2.0.

These transformers will be used by Edmonton Power, at their Clover Bar Generating Station.

J. Armstrong
Acting Chief
Electricity and Gas Division
Legal Metrology Branch

cc: Mr. F.W. Nash
District Manager (E & G)
Edmonton, Alberta

Edmonton Power (through Mr. Nash)