



Consumer and
Corporate Affairs

Consommation et
corporations

Consumer
Standards
Directorate

Direction
générale
des normes

SPE-382
OTTAWA, Ontario
K1A 0C9

G6565-C4-32

Your file / Votre référence

Our file / Notre référence

24 April 1980

SPECIAL APPROVAL

Granted to: ASEA Limited
The Bentall Centre
P. O. Box 49038
Vancouver, B.C.

Attention: Mr. F. A. da Costa
Power Department

Subject: Three only, ASEA Type IMBD-145-A4
300x600-5-5-5-5A, 60Hz Current Transformers
Serial Nos.: 7171836, 7171837 and 7171838

Special approval has been granted by the Legal Metrology Branch for use of the subject transformers on the "X" and "Y" secondary coils for revenue metering in Canada.

These transformers are similar in design to those approved under Notice of Approval T-64. The primary winding is in two sections and provision is made for connecting them in series or in parallel to obtain the double ratio rating 300X600-5A.

The accuracy rating is 0.3B1.0 for the approved ratios which are obtained from the secondary terminals X1-X2 and Y1-Y2.

The subject transformers will be used by West Kootenay Power and Light Company Limited, Trail, B.C.

J. Armstrong
Acting Chief
Electricity and Gas Division
Legal Metrology Branch

TL/lm

cc: Mr. W. Pura
District Manager (E & G)
Vancouver, B. C.

West Kootenay Power & Light Co. Ltd.
(via Mr. Pura)