



Ottawa, Ontario
July 3, 1980

6565-9
6565-1

SPECIAL APPROVAL

Granted To: Oshawa P.U.C.
100 Simco St. South
Oshawa, Ontario
L1G 7M7

Attention: Mr. L.A. Algar
Manager, Oshawa P.U.C.

Subject: Installation of Automatic Meter Reading
Equipment, (Trial).

Special Approval is hereby granted by the Director of Legal Metrology to Oshawa Public Utilities Commission for installation of automatic meter reading encoders on a selected number of domestic meters.

The modification consists of replacement of the test dial by a disc magnet. A Hall effect device is secured by screw attachment to the register face adjacent to the magnet.

The leads from the transducer are connected to a three pin male connector mounted on the base plate of the meter.

The purpose of this trial which will involve up to 500 residential and commercial customers is to perform a load management study.

Approval of this modification is based on the assumption that the regular manual meter readings will be used for billing purposes.

J. Armstrong
Acting Chief
Electricity & Gas Division

cc: Mr. M.D. Raaflaub
District Inspector, E&G

Mr. J.R. McRae
Supervisor, Load Management Department
Ontario Hydro